

EC Declaration of Conformity

MANUFACTURER:- STATUS INSTRUMENTS LTD
Green Lane,
Tewkesbury,
Gloucestershire,
GL20 8DE
UK

Hereby declares that the following apparatus :

NAME:- Head Mounted Temperature Transmitters

TYPE:-
SEM205X
SEM210X

Are in conformity with the following directives and standards:

EMC DIRECTIVE:- EMC directive 2004/108/EC and later amendments

STANDARD:- BS EN 61326-1 : 2006

ATEX DIRECTIVE:- 94/9/EC

STANDARDS:-
EN 60079-0 : 2009
EN 60079-11 : 2007
EN 60079-26 : 2007

ATEX CERTIFICATION CODE:-   II 1 G EEx ia IIC T4..T6

Ta = (-25 to +40) °C for T6
Ta = (-25 to +50) °C for T5
Ta = (-25 to +85) °C for T4

ATEX NOTIFIED BODY:-
TRaC
Nipe Lane
Up Holland
Lancashire
WN8 9PY
UK

MANUFACTURERS SIGNATURE:-

Signed



Ian Pullin

Managing Director

Date: 15th April 2010