

# EC Declaration of Conformity

---

**MANUFACTURER:-** STATUS INSTRUMENTS LTD  
Green Lane,  
Tewkesbury,  
Gloucestershire,  
GL20 8DE  
UK

**Hereby declares that the following apparatus :**

**NAME:-** Head Mounted Temperature Transmitters

**TYPE:-**  
SEM205X  
SEM210X

**Are in conformity with the following directives and standards:**

**EMC DIRECTIVE:-** EMC directive 2004/108/EC and later amendments

**STANDARD:-** BS EN 61326-1 : 2006

**ATEX DIRECTIVE:-** 94/9/EC

**STANDARDS:-**  
EN 60079-0 : 2009  
EN 60079-11 : 2007  
EN 60079-26 : 2007

**ATEX CERTIFICATION CODE:-**   II 1 G EEx ia IIC T4..T6

Ta = (-25 to +40) °C for T6  
Ta = (-25 to +50) °C for T5  
Ta = (-25 to +85) °C for T4

**ATEX NOTIFIED BODY:-** TRaC  
Unit 1 Pendle Place,  
Skelmersdale,  
West Lancashire,  
WN8 9PN,  
UK

**MANUFACTURERS SIGNATURE:-**

Signed



Ian Pullin

Managing Director

Date: 15<sup>th</sup> April 2010