

CE Declaration of Conformity

Name of Manufacturer [Status Instruments Ltd](#)
Address: [Status Business Park, Gannaway Lane, Tewkesbury, Gloucestershire.](#)
Country: [United Kingdom](#)

Declare under our sole responsibility that the following apparatus:

Product description: [In head two wire \(4 to 20\)mA temperature transmitters](#)
Model or Type No.: [TTR200X, TTC200X](#)

Product description: [Rail mounted two wire \(4 to 20\)mA temperature transmitters](#)
Model or Type No.: [SEM1801XTC, SEM1802XTC, SEM1801XR, SEM1802XR](#)

Are in conformity with the following relevant EC legislation:

[ATEX directive 94/9/EC](#)
[EMC directive 2004/108/EC](#)

Based on the following harmonised standards:

EN 60079-0:2006	EN 60079-11:2007
EN 61241-0:2006	EN 61241-11:2006
EN 60079-26:2007	EN 61326-11:2013

And the following non-harmonised standards:

[N/A](#)

And therefore complies with all of the relevant essential requirements of those directives.

The following Notified Body has been involved in the conformity assessment process:

Notified Body [TRaC EMC & Safety Ltd](#)
Notified Body No. [0891](#)
Role: [Issue of ATEX EC Type Examination certificate](#)
Certificate No. [TRAC09ATEX11232X](#)

Additional information:

ATEX coding	IECEX TRC 10.0008X	Ex ia IIC T4 Ga
	TTR200X, TTC200X	Ex iaD 20 T135 °C Da
	SEM1801XR, SEM1802XR, SEM1801XTC, SEM1802XTC	Tamb = -40°C to +85°C
		Tamb = -40°C to +70°C

Name and position of person binding the manufacturer or authorised representative:

Signature



Name [I Pullin](#)
Function [Managing Director](#)
Location [Status Instruments Ltd](#)
Date of issue [2013-03-11](#)