

EU Declaration of Conformity



Product name – SEM1801/2XTC

Description – Atex Rail temperature transmitter for thermocouple and mV sensors

Status Instruments Ltd, located at Status Business Park, Gannaway Lane, Tewkesbury, Gloucestershire GL20 8FD, United Kingdom, hereby declares, under the sole responsibility of the manufacturer, that our product complies, by application of the harmonised standards and directives below:

EMC Directive 2014/30/EU

EN 61326-1:2013 and later amendments

Table 2 industrial environments

RoHS Directive 2011/65/EU incorporating RoHS3 amendment Directive EU 2015/863

EN IEC 63000:2018

ATEX Directive 2014/34/EU & UK SI 2016/1107

Certificate ExVeritas 25ATEX2063X

Notified Body No. 2804

EN 60079-0:2018 +A11:2024

EN 60079-11:2012

The equipment is marked with the following:

II 1 G D

Ex ia IIC T4 Ga

Ex ia IIIC T135 DEG C Da

EN 60529:1992+A2:2013 Degrees of protection provided by enclosures (IP Code)

Refer to the Product data sheets on the Status Website for specific IP ratings

Signed:

A handwritten signature in black ink, appearing to be 'M J White', written over a light blue horizontal line.

Title: COMPLIANCE ENGINEER

Signed:

A handwritten signature in black ink, appearing to be 'J S Lee', written over a light blue horizontal line.

Title: MANAGING DIRECTOR

(For and on behalf of *Status Instruments Ltd*)

Date: 20.11.2024

Place: Tewkesbury, UK